Job Name/Location: Tag #:

| Date:      | For: File Resubmit |
|------------|--------------------|
| PO No.:    | Approval Other     |
| Architect: | GC:                |
| Engr:      | Mech:              |
| Rep:       |                    |
| Company)   | (Project Manager)  |



## LMU187HV

## Multi F Inverter Heat Pump Outdoor Unit

## Performance:

| Nominal Cooling Capacity (Btu/h) | 18,000 |
|----------------------------------|--------|
| Cooling Power Input (kW)         | 1.12   |
| Heating Power Input (kW)         | 1.29   |

Cooling Nominal Test Conditions: Heating Nominal Test Conditions: Indoor: 80°F DB/67°F WB Indoor: 70°F DB/60°F WB
Outdoor: 95°F DB/75°F WB Outdoor: 47°F DB/43°F WB

## **Electrical:**

| Power Supply (V¹/Hz/Ø) | 208-230/60/1 |
|------------------------|--------------|
| MOP (A)                | 15           |
| MCA (A)                | 11.0         |
| Cooling Rated Amps (A) | 11.4         |
| Heating Rated Amps (A) | 11.9         |
| Compressor (A)         | 8.2          |
| Fan Motor (A)          | 0.40         |

MOP - Maximum Overcurrent Protection MCA - Minimum Circuit Ampacity

### Piping:

| Refrigerant Charge (lbs)                 | 4.19         |
|--|--------------|
| Liquid Line (in, OD)                     | 1/4 (2 Each) |
| Vapor Line (in, OD)                      | 3/8 (2 Each) |
| Max Total Piping (ft) <sup>2</sup>       | 164.0        |
| Max ODU to IDU Piping (ft)               | 82.0         |
| Piping Length (no add'l refrigerant, ft) | 49.2         |
| Max Elevation between ODU and IDU (ft)   | 49.2         |
| Max Elevation between IDU and IDU (ft)   | 24.6         |

ODU - Outdoor Unit IDU - Indoor Unit

#### **Controls Features:**

•Auto operation
•Auto restart operation
•Auto restart operation

•Low ambient operation to

14F (cooling mode)

Defrost/Deicing
 Restart delay (3-minutes)
 Inverter (variable
 Self diagnosis

Inverter (variable speed compressor)Self diagnosSoft start

## **Optional Accessories:**

PI-485 Integration Board - PMNFP14A0

AC Smart Premium - PQCSW421E0A

AC Ez - PQCSZ250S0

Power Distribution Indicator - PQNUD1S00

For a complete list of available accessories, contact your LG representative.

## **Operating Range:**

| Cooling (°F DB) | 14-118 |
|-----------------|--------|
| Heating (°F WB) | 0-64   |

#### **Unit Data:**

| Refrigerant Type                                 | R410A    |
|--|----------|
| Refrigerant Control                              | EEV      |
| Sound Pressure <sup>3</sup> (Cool/Heat) ±3 dB(A) | 51/51    |
| Net Unit Weight (lbs)                            | 124      |
| Shipping Weight (lbs)                            | 133      |
| Heat Exchanger Coating                           | GoldFin™ |
| Min Number of Indoor Units                       | 2        |
| Max Number of Indoor Units                       | 2        |
|  |          |

#### **Compressor:**

| Quantity | 1                    |
|----------|----------------------|
| Туре     | Twin-Rotary Inverter |
| Oil/Type | FVC68D               |

### Fan:

| Туре               | Propeller                             |
|--------------------|---------------------------------------|
| Quantity           | 1                                     |
| Fan Motor/Drive    | Brushless Digitally Controlled/Direct |
| Airflow Rate (CFM) | 2,119                                 |

#### Notes:

- 1.Acceptable operating voltage: 187V-253V.
- 2.Piping lengths are equivalent.
- 3. Sound Pressure levels are tested in an anechoic chamber under ISO Standard 1996.
- 4.All power/communication cable to be minimum 18 AWG, 4-conductor, stranded, shielded and must comply with applicable local and national code.
- 5.Power wiring cable size must comply with the applicable local and national code. 6.See Engineering Manual for sensible and latent capacities.
- 7. Power wiring cable size must comply with the applicable local and national code. 8. This data is rated 0 ft above sea level, with 24.6 ft of refrigerant line and a 0 ft level difference between outdoor and indoor units. All capacities are net with a combination
- ratio between 95 105%.

  9.Refer to the Engineering Product Data Book for combination capacity tables.
- 10.The outdoor unit combined with non-ducted indoor units qualifies for Energy Star.
- ${\bf 11.} \\ Must follow in stallation instructions in the applicable LG in stallation manual.$









# LMU187HV


## Multi F Inverter Heat Pump Outdoor Unit



Tag #:
Date:







| 7                       | 6                          | 5           | 4                               | ω                      | 2                   | -1                   | No.       |
|-------------------------|----------------------------|-------------|---------------------------------|------------------------|---------------------|----------------------|-----------|
| Main service valve(Gas) | Main service valve(Liquid) | Earth screw | Power & transmission connection | Liquid pipe connection | Gas pipe connection | Air discharge grille | Part Name |
|                         |                            |             |                                 |                        |                     |                      | Remarks   |